

Facility Name: FUEL STAR BEACON

FA ID # 137

Pg 2 of 2

Date of Inspection: 4/4/16

OBSERVATIONS AND CORRECTIVE ACTIONS

21. ADJUST HOT WATER HEATER TO MAINTAIN 120°F MINIMUM. BOTH 3-COMPARTMENTS
↓ HANDWASH SINK @ 105°F @ TIME OF INSPECTION

Received by (Print)

Hannah Kingsland

Title

Received by (Signature)

Hannah Kingsland

Specialist (Print)

PAT SANDERS

Specialist (Signature)

[Signature]

Re-inspection Date: