

Facility Name:

GRAPE FLOTH

FA ID #

114

Pg 2 of 2

Date of Inspection:

22 OCT 19

OBSERVATIONS AND CORRECTIVE ACTIONS

#21) INCREASE TEMP OF HOT WATER TO 120°F (FOUND AT 112°F)

Received by (Print)

Title

Received by (Signature)

Specialist (Print)

Specialist (Signature)

Re-inspection Date: