


EROSION CONTROL MEASURES

1. All culverts, ditches, and gutters shall be sized for a 1-hour, 25-year frequency storm.
2. Vegetation removal, clearing, and grading shall entail no more than is prudent for construction of those facilities necessary for the use and enjoyment of the property, in the opinion of the County Engineer. Clearing and grading activities shall be limited to six dry summer months (May 1 through October 31). Tree and brush remains shall be chipped and spread rather than burned. Earth-disturbing activities outside of this season will necessitate preparation and approval of an interim plan providing temporary construction erosion-control measures.
3. Cut slopes shall be no steeper than 1 to 1 unless stable rock is present in the opinion of the County Engineer.
4. Untreated fill slopes shall be no steeper than 1.5 to 1; slopes up to 1 to 1 may be permitted in specific instances where the County Engineer determines that stability is not compromised, in which case erosion control measures in the form of rock rip-rap and/or stapled erosion-control blankets (Excelsior "Standard Plus" by Contech or equivalent) will be installed.

WEST ALMANOR HEIGHTS UNIT ONE

ADDITIONAL INFORMATION
IN SECTION 33, T.28N, R.7E., M.D.B. & M.
PLUMAS COUNTY, CALIFORNIA



NST ENGINEERING ASSOCIATES, INC.
45 SO. ROOP STREET
SUSANVILLE, CALIF. 96130
916-257-5173

SHEET 6 OF 6